

installations can be a safety hazard if co-located on primary electric poles. The majority of our exposed primary electric lines carry 7,200 volts. The National Electric Safety Code has some language regarding safe installation of telecommunication facilities near energized electric lines. However, the language in that code, as well as the language in our current utility policy, is vague and does not really address wireless attachments at all. In the interest of public health, safety and welfare and for safe and reliable operation of our electric distribution system, Staff recommends the Council adopt the following language to be inserted into the City of Boerne Utilities Rules and Regulations. No foreign attachments on City owned primary or secondary electric distribution poles shall be made without prior consent of the City per the terms of a valid joint-use agreement with the City. The top 10 feet of all City owned primary electric distribution poles is reserved Electric Distribution Space for the exclusive use of the City's electric facilities. No wired or wireless contacts by others will be allowed within or above that space. No telecommunication attachments shall be allowed within 40 inches of energized electric facilities (the telecommunications safety space). To ensure safety, no telecommunication contacts shall extend vertically into or through the 40 inch telecommunication safety space on City owned primary electric distribution poles. • Foreign attachments shall be made in full and complete compliance with all other applicable requirements of the effective NESC, AASHTO, TxDOT or any other applicable regulatory requirements and per our joint-use agreements.

COST	N/A
SOURCE OF FUNDS	N/A
ADDITIONAL	
INFORMATION	

This summary is not meant to be all inclusive. Supporting documentation is attached.